

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor

Aaron Olver, Secretary

August 10, 2010

PFS RON REINDL 1507 MATT PASS COTTAGE GROVE WI 53527 VERTICAL WORKS INC ANDREW D. JANSEN 3834 E PUETS RD OAK CREEK WI 53154

Re: Description: PREFABRICATED PLUMBING SYSTEM

Manufacturer: VERTICAL WORKS INC

Product Name: PREFABRICATED PLUMBING

Model Number(s): SANI-SG-1 Product File No: 20100282

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2015.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 25 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
  department's stamp of approval. The plans and specifications must be open to inspection by an authorized
  representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means
  concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in
  a modular building component, which will not be visible for inspection when delivered to the final site of
  installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 10028204.DOC